

STATE OF NEW HAMPSHIRE
BUREAU OF PURCHASE AND PROPERTY
STATE HOUSE ANNEX
25 CAPITOL STREET
CONCORD, NEW HAMPSHIRE 03301-6398

ADDENDUM # 1 TO BID INVITATION # 268-16

DATE OF BID OPENING: 6/2/16

TIME OF BID OPENING: 11:00 AM (EST)

FOR: PRESTRESSED CONCRETE BEAMS

QUESTIONS AND ANSWERS

QUESTION #1

Please confirm if we are to included materials, equipment and labor to post-tension the beams in the field.

ANSWER #1

Post-tensioning materials will be provided and installed by others.

QUESTION #2

Please confirm if we are to include the supply of the (08) embedded railing anchor plates assemblies or will they be provided by others.

ANSWER #2

Rail anchorage plates, anchor studs, and nuts will be provided by others and installed by the precaster.

QUESTION #3

Prestressed Beam Note #2 on Sheet 2 specifies that the fabricator is to provide design calculations for the beams w/ a NH PE seal. Given that the drawings specify a reinforcement design, is this really the intent?

ANSWER #3

There should not have been a period after "Hardware". The intent is the precaster will prepare and stamp calculations and plans for the lifting hardware only.

QUESTION #4

Referencing the interior and exterior reinforcement sections at 5' on Sheet 2, the outermost bottom prestressing strands are located 2 3/4" in from the edge of the beams. We will not be able to maintain the specified 2" clear to the #4 stirrups with the proper bend radius on the stirrups. Please confirm we can move these two strands in an additional 2" to avoid the conflict.

ANSWER #4

The outermost strands should be placed at 4-3/4" from the edge of the beams, not the 2-3/4" shown.

QUESTION #5

Please confirm the length of the indicated deboned strands on Sheet 2.

ANSWER #5

The strands should be deboned 2' – 6"

PURCHASING AGENT: Robert Lawson
TEL. NO.: 603/271- 3147

NOTE: IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER _____ ADDRESS _____

BY _____

(this document must be signed)

_____ TEL. NO. _____

(please type or print name)

Please visit: <http://das.nh.gov/purchasing>
(click on "Bid, Proposals...") for complete bid and addendums.